
A d d e n d u m t o 7 7 8 8 F M a n u a l

DATE: Mar 14, 2014
FROM: DIRECTOR OF OPERATIONS
AES Corporation

PHONE: (978) 535-7310
FAX: (978) 535-7313

1. MANUAL: 40-7788 / Revision 4/ Date of Publication—Mar 12, 2014/ Page 12
2. PRODUCT: 7788F RF Subscriber Unit
3. Alternate antennas may be used with the 7788F Fire Subscriber unit. Contact AES for a selection of antennas suitable for use with your subscriber radio.
4. The antenna must be installed in accordance with National Electric Code and local electric code. NFPA 72 requires antenna cables to be installed in conduit. A protective surge arrester, AES P/N 52-0054, must be installed in line with any type of remotely installed antenna. Please refer to the drawing below for installation details.
5. Please attach this addendum to page 12 of the manual.

