

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-1516:0106 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: AES CORPORATION 285 NEWBURY ST, PEABODY, MA 01960
Contact: Justin Mitchell (978) 839-7063 Fax (978) 535-7313
Email: jmitchell@aes-corp.com

DESIGN: Models 7770 Serial Data Converter. This unit is supplemental add-on equipment for Model 7744 or 7788 RF subscriber unit. It takes contact ID information provided by the control unit's RS-232 port connected to the RS-232 port of the 7744 or 7788 unit. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 12 V DC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as miscellaneous devices for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

03-26-2009 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division