

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7300-1516:0108

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: AES CORPORATION 285 NEWBURY ST, PEABODY, MA 01960
Contact: Justin Mitchell (978) 839-7063 Fax (978) 535-7313
Email: jmitchell@aes-corp.com

DESIGN: *Model 7788F Subscriber Unit, RF transceiver. Unit is intended for use with listee's separately listed Model IntelliNet 7705i system (7300-1516:104) and 7170-EM IPLinks, Remote Transceivers (7300-1516:105). Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 120 VAC, 16.5 VAC 40VA Secondary, 12 VDC nominal

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, and UL label.

APPROVAL: Listed as a two-way transceiver unit for use with separately listed compatible fire alarm control units.

* 07-12-2013 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division