

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7300-1516:0109 Page 1 of 1

**CATEGORY:** 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

**LISTEE:** AES CORPORATION 285 NEWBURY ST, PEABODY, MA 01960  
Contact: Justin Mitchell (978) 839-7063 Fax (978) 535-7313  
Email: [jmitchell@aes-corp.com](mailto:jmitchell@aes-corp.com)

**DESIGN:** Model 7794 (FirePro) Digital Dialer Interface. Model is intended for use with 7744F and 7788F subscriber unit and as a supplemental use. It takes industry standard communication formats provided by the FACP units' DACT and transfers the data to the subscriber unit where it is transmitted to the AES MultiNet Receiver System. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 12V dc

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as miscellaneous devices for use with separately listed manufacturer's Model 7744F and 7788F subscriber unit. Refer to listee's Installation Instruction Manual for details.

07-07-11 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

*Listing Expires* **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**  
*Fire Engineering Division*