

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7300-1516:0501 Page 1 of 1

**CATEGORY:** 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

**LISTEE:** AES CORPORATION 285 NEWBURY ST, PEABODY, MA 01960  
Contact: Justin Mitchell (978) 839-7063 Fax (978) 535-7313  
Email: [jmitchell@aes-corp.com](mailto:jmitchell@aes-corp.com)

**DESIGN:** AES Model 7707 Subscriber Unit, one-way RF receiver and listed accessories intended to be connected to a separately listed fire alarm control unit. Accessories listed for use with this unit are subassembly modules 7711 and 7712, and 7794A digital dialer interface. Refer to listee's Installation Instruction Manual for details.

**RATING:** 120 VAC, 60Hz, 1.75 Amp  
24VDC, 1.3 Amp

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as a subscriber unit for use with separately listed AES Model 7705i receiver (CSFM # 7300-1516:0104) and Model 7170 IP-Link (CSFM # 7300-1516:0105).

05-19-2017 dcc



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

*Listing Expires* **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**  
*Fire Engineering Division*