

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7300-1516:0504 Page 1 of 1

**CATEGORY:** 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

**LISTEE:** AES CORPORATION 285 NEWBURY ST, PEABODY, MA 01960  
Contact: Justin Mitchell (978) 839-7063 Fax (978) 535-7313  
Email: [jmitchell@aes-corp.com](mailto:jmitchell@aes-corp.com)

**DESIGN:** Model 7094A (IntelliPro) Digital Dialer Interface Unit. Intended for indoor use only.

Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 12 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances, NFPA 70, NFPA 72, and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, date of manufacture, and UL label.

**APPROVAL:** Listed as a miscellaneous device for use with listee's separately listed compatible Model 7007 RF Security Subscriber Unit (7300-1516:0503), Model 7705i or 7705ii Central Station Receiver (7300-1516:0104), and Model 7170 IP-Link System (7300-1516:0105). Refer to listee's Installation Instruction Manual for details.

04-20-20 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

*Listing Expires* **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**  
*Fire Engineering Division*