

7704-DMS Dedicated Monitoring System

FREQUENTLY ASKED QUESTIONS



Q: Is this a standalone system or does it need to be hooked up to an existing AES Subscriber?

A: The 7704-DMS Dedicated Monitoring System is a standalone system. It combines the functionality of an AES Subscriber (communicator) with a fire panel and is intended to monitor small fire system applications, such as a commercial sprinkler system.

Q: What devices are compatible with this system?

A: The 7704-DMS is compatible with the following manufacturers' devices: System Sensor®, Hochiki®, Potter®, and GENTEX®. Please refer to the manual for a complete list of devices.

Q: How many devices can I hook up to this system?

A: The total number of devices can range depending on how many Initiating Device Circuit (IDC) or Notification Appliance Circuit (NAC) you need to configure. Please refer to the *Battery Calculator* found at: aes-corp.com/product/7704-dms-dedicated-monitoring-system.

Q: How much power can be used for NAC devices?

A: The 7704-DMS offers 0.5 Amps of NAC power.

Q: Does this system connect to Class A or Class B devices?

A: This system is designed for Class B, 2-wire sensors.

Q: How do you silence or reset this system?

A: There is a silence/reset button located inside the enclosure.

Q: Is the Dedicated Monitoring System certified for Canada?

A: No. At this point in time the Dedicated Monitoring System has only been tested/approved for US markets.

Q: Is this product UL listed?

A: The 7704-DMS system has been tested by Intertek to the UL 864 Standard. [Follow this link](#) to learn more about Intertek (ETL) vs. UL Listings.

Q: Is the 7704-DMS Dedicated Monitoring System CSFM and FDNY approved?

A: Yes. The 7704-DMS Dedicated Monitoring System is both CSFM and FDNY approved.

