



Technical Bulletin 007

July 7, 2026

Product(s): AES Model 7788, 7744, 7707, & 7177

Title: Monitoring Fire Alarm Control Panel Relays with the AES IntelliNet Subscriber

The AES IntelliNet subscriber and IntelliPro Accessory Board provide fire alarm control panels with a DACT interface for signal delivery on the AES RF mesh network.

Monitoring fire alarm control panels that cannot be programmed to periodically report to a central monitoring station is done using the AES Model 7711 Eight Zone Input card.

Using the wiring diagram below, connect the dry contact relays from the fire alarm control panel to the Model 7711 zone inputs. Configure the AES subscriber to report status change.

